

Outlet parameters

BOD at 20 C	30
Chlorine free residue	0.1
Oil and Grease	Nil
PH	6.5 - 8.5
TSS	30
Temp based on ambient temp	± 3
Sulphide	0.1
COD	50

Inlet Parameters

	SM1	SM2	SM3	SM4	SM5
pH	7.02	7.03	6.99	9.18	7.04
Colour	>70	>70	>70	>70	>70
BOD at 20 C	1457	1348.4	1258.5	1407.6	1278.8
TSS	349	102.41	306.49	306.6	364
Oil and Grease	34	15.68	48.46	26.14	30.16
Residual chlorine	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Sulphate	415	89.5	12.5	36.8	26.07

